



HVAC System Case Study



η-Power Solutions
Pima Controls Pvt. Ltd.

Case Study – 100HP Air Handling Unit

Occupancy Schedule


Time of the Day (Hours)	0000 - 0600	0600 - 0800	0800 - 1200	1200 - 1300	1300 - 1700	1700 - 2000	2000 - 2400
Occupancy % Wk days	0	20	95	45	95	20	5
Occupancy % Wk ends	0	5	10	10	10	10	5

Make up Air Handling Unit

Source: Ralph J Ferraro, PE - Ferraro, Oliver and Associates, Inc.
Andrew Jackson Building - Nashville, TN VFD Evaluation

Case Study – 100HP Air Handling Unit

Recommended Air Volume



Recommended Condition




Existing Condition



Source: Ralph J Ferraro, PE - Ferraro, Oliver and Associates, Inc.
Andrew Jackson Building - Nashville, TN VFD Evaluation

Case Study – 100HP Air Handling Unit

Recommended Air Volume



Recommended Condition

--- Existing Condition



Source: Ralph J Ferraro, PE - Ferraro, Oliver and Associates, Inc.
Andrew Jackson Building - Nashville, TN VFD Evaluation

Case Study – 100HP Air Handling Unit

Total energy cost savings

$$\begin{aligned} &= (\text{Present cooling energy cost} + \text{present heating energy cost} + \\ &\quad \text{present electricity cost}) - (\text{Post VFD implementation cooling} \\ &\quad \text{energy cost} + \text{heating energy cost} + \text{electricity cost}) \\ &= (\$71,186 + \$45,490 + \$27,577) - (\$23,357 + \$14,934 + \\ &\quad \$12,310) \\ &= \$144,253 - \$50,601 = \mathbf{\$93,652} \end{aligned}$$

Source: Ralph J Ferraro, PE - Ferraro, Oliver and Associates, Inc.
Andrew Jackson Building - Nashville, TN VFD Evaluation



Case Study – 100HP Air Handling Unit

Estimated Total Building Energy savings

Electrical.....439,776 KWh/year

Chilled Water.....434,810 Ton-hr/yr


Steam.....3,055,671 lbs/yr

Source: Ralph J Ferraro, PE - Ferraro, Oliver and Associates, Inc.
Andrew Jackson Building - Nashville, TN VFD Evaluation



Case Study – 100HP Air Handling Unit

Estimated Total Building Energy Savings



Recommended Condition



Existing Condition

Source: Ralph J Ferraro, PE - Ferraro, Oliver and Associates, Inc.
Andrew Jackson Building - Nashville, TN VFD Evaluation

Case Study – 100HP Air Handling Unit

Payback For The System

- Straight-line payback = (construction cost) / (annual energy cost savings)

- 100 hp electronic 12 Pulse VFD @\$25,000
- 100 hp installation cost @.....\$20,000
- Engineering design cost @.....\$15,000

w/installation specs, layout, &
interconnection drawings

Straight-line payback = \$60,000/\$93,652 = **0.64 years**

NOTE: Standard VFD w/ 6 Pulse Rectifier lowers hardware cost to \$15,000 and reduces payback to 0.53 years

Source: Ralph J Ferraro, PE - Ferraro, Oliver and Associates, Inc.
Andrew Jackson Building - Nashville, TN VFD Evaluation

